

NOTE:

VALVE BOXES SET IN ROAD SHOULDERS, FIELDS, ETC. SHALL BE AS SHOWN IN DETAIL "A".

APPROVED GATE VALVES


6" - 10"		
CLOW F-5082		MUELLER A-2380-24
KENNEDY 573X		MUELLER A-2370-26
M & H 67 RT, O-RING		WATEROUS SERIES 500
12" AND OVER		
MUELLER A-2370-26		WATEROUS SERIES 500

ALL VALVES SHALL BE A.W.W.A. APPROVED RESILIENT WEDGE

CITY of CORCORAN • Department of Public Works

Standard Drawing for:

VALVE WELL & COVER

APPROVED:  05/19/08
Date

Revised:

W-2