

CONTRACTOR QUESTIONS

FOR THE

CITY OF CORCORAN

**2020 MICRO-SURFACING AND STREET
IMPROVEMENTS PROJECT**

August 31, 2020



OWNER:

**City of Corcoran
832 Whitley Avenue
Corcoran, CA 93212
(559) 992-2151**

PREPARED BY:

**A&M
310 W Murray Avenue
Visalia, CA 93291
(559) 429-4747**


CONTRACTOR QUESTIONS:

Q1: Sheet 9 shows City Standard Details for Chain Link Fencing M-10 and M-11. Both note chain link “2-inch mash, 2 gauge” should this be “2-inch mesh, 9 gauge”?

A1: Yes, the City Standard for Chain-link Fencing will be Galvanized Chain-link 2-inch mesh, 9 gauge.

--

NOTE: One copy of this Contractor Questions Document shall be signed by the Contractor and must be submitted with the bid as acknowledgement of receipt and the acceptance of this Contractor Questions Document.

Prepared by:  August 31, 2020
Orfil Muniz, P.E. Date
A&M Consulting Engineers

Accepted by: _____
Contractor (signature) Date